

Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name: Placer County Water Agency-Monte Vista

Water Supplier ID Number: 3110124

Water Audit Period: 1/2019-12/2019

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

The PCWA water auditor will be collaborating with treatment plant operators to better quantify the unbilled unmetered amounts.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)


Executive Position

Signature

Date

R. Brent Smith P.E.

Director of Technical Services



October 19, 2020

Utility Provided

Appendix B

Certified Validation Report Template, Part A: Provided by Validator

Audit Information:

Water Supplier Name: Placer County Water Agency-Monte Vista
PWS ID: 3110124
System Type: Potable
Audit Period: January 2019-December 2019
Utility Representation: Randy Cox
Validation Date: October 11, 2020
Call Time: 10:000 a.m.
Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 52
Data Validity Band (Level): 3
ILI: Not applicable
Real Loss: 10.65 gallons/mile/day or 0.010 acre feet/year
Apparent Loss: 56.16 gallons/connection/day or 1.007 acre feet/year
Non-revenue water as percent of cost of operating system: 1.8%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☐

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator: Amy Talbot

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided